



FIRE EXTINGUISHERS

Page 1 of 1

Mackinac Island State Park Commission
Rule and Policy

Fire Extinguishers

Rule 46 (7), R 318.146 of Mich. Admin. Code

Minutes: June 8, 1979, P. 1782

Preamble:

It is unlawful for any lessee, licensee, or concessionaire to use, construct, or occupy any building within the park not furnished with an approved dry chemical fire extinguisher. (Rule 46 (7), R 318.146 of the Michigan Administrative Code).

General Policy

The approved extinguisher is a 5 lb. minimum ABC type, one extinguisher to be located in a readily accessible place on each floor of a building and to be inspected annually. (Minutes, June 8, 1979, p. 1782).